Autonics

TEMPERATURE CONTROLLER TOM/TDM SERIES



Thank you very much for selecting Autonics products. For your safety, please read the following before using.

Caution for your safety

*Please keep these instructions and review them before using this unit.

*Please observe the cautions that follow:

Marning Serious injury may result if instructions are not followed.

⚠ Caution Product may be damaged, or injury may result if instructions are not followed.

*The following is an explanation of the symbols used in the operation manual. ▲ caution: Injury or danger may occur under special conditions.

∧ Warning

- 1. In case of using this unit with machineries(Nuclear power control, medical equipment, vehicle, train, airplane, combustion apparatus, entertainment or safety device etc), it requires installing fail-safe device, or contact us for information on type required.
- It may result in serious damage, fire or human injury 2. This unit must be mounted on panel.
- It may give an electric shock
- 3. Do not repair or checkup when power on.
- may give an electric shock.
- 4. Do not disassemble and modify this unit, when it requires. If needs, please contact us.
- It may give an electric shock and cause a fire.
- 5. This product is a combined use of 110/220VAC, please check the terminal when connect.

It may cause a fire.


∧ Caution

- 1. This unit shall not be used outdoors.
- It might shorten the life cycle of the product or give an electric shock
- 2. When wire connection, No.20AWG(0.50mm 2) should be used and screw bolt on terminal block with 0.74N · m to 0.90N · m strength. It may result in malfunction or fire due to contact failure
- 3. Please observe specification rating.
- It might shorten the life cycle of the product and cause a fire
- 4. Do not use the load beyond rated switching capacity of Relay contact.
- It may cause insulation failure, contact melt, contact failure, relay broken, fire etc.
- 5. In cleaning the unit, do not use water or an oil-based detergent. might cause an electric shock or fire that will result in damage to this product.
- 6. Do not use this unit at place where there are flammable or explosive gas, humidity, direct ray of the sun, radiant heat, vibration, impact etc.
- 7. Do not inflow dust or wire dregs into inside of this unit.
- 8. Please wire properly after checking the polarity of terminals when connect thermocouples.

It may cause a fire or explosion


t may cause a fire or explosion

Dimensions



discontinued without notice.


Ordering information



Specifications

Model		TOM	TDM			
Power su	ypdy	110/220VAC 50/60Hz				
Allowable range	e voltage	90 to 110% of rated voltage				
Power co	onsumption	3VA				
Display r	method	LED ON/OFF indicator	LED deviation indicator			
Setting r	nethod	Digital setting				
Setting accuracy		F • S ±2%				
Sensor ii	nput	Thermocouples:K(CA), J(IC) / RTD:Pt100Ω				
Input line resistance		Thermocouples:Max. 100Ω, RTD:Max. 5Ω per a wire				
Control	ON/OFF	Hysteresis:F • S 0.5 ±0.2% fixed□				
Control	Proportional	Proportional band:F • S 3% fixed, Period:20sec. fixe				
Control	output	 Relay contact output:250VAC 3A 1c SSR output:12VDC ±3V 20mA Max. 				
Self-diagnosis		Built-in burn out function				
Insulation resistance		Min. 100MΩ(at 500VDC)				
Dielectric strength		2000VAC 50/60Hz for 1 minute				
Noise strength		± 2 kV the square wave noise(pulse width:1 μ s) by the noise simulator				
Vibration	Mechanical	0.75mm amplitude at frequency of 10 to 55Hz in each of X, Y, Z directions for 1 hour				
vibration	Malfunction	0.5mm amplitude at frequency of 10 to 55Hz in each of X, Y, Z directions for 10 minutes				
Shock	Mechanical	300m/s² (Approx. 30G) 3	times at X, Y, Z direction			
	Malfunction	100m/s² (Approx. 10G) 3	times at X, Y, Z direction			
Relay	Mechanical),000 times			
life cycle	Electrical	Min.100,000 times (250VAC 3A resistive load)				
Ambient temperature		-10 to 50℃(at non-freezing status)				
Storage temperature		-25 to 65℃(at non-freezing status)□				
Ambient	humidity	35 to 85%RH				
Weight		Approx. 419g	Approx. 461g			

Connections




Temperature range for each sensor

	Model		TOM / TDM											
Г	Sensor input type		Thermocouples				RTD							
			J(IC)		K(CA)				Pt100Ω					
	Standard scale range(°C)	1600 1200 1000 800 600 400 200 100 0	300°C 200°C	0°C	200	- 30 - 30 - C		60 0°C	0°0 0°0 	120 		200 100°C		0°C

ON/OFF control

The drawing shows that the output turns on when the temperature is lower than the set value. (Heater ON) The output turns off when temperature is equal or higher than the set value. (Heater OFF)




As like above picture, the control value is up and down by set value, it is called Hunting. And Overshoot is occurred at initial point when just

If the Hunting and Overshoot is less, it will be a good control


Hysteresis

The ON/OFF control has hysteresis due to reduce the chattering or noise affection. Generally make hysteresis bigger for compressor for cooler due to this reason



Ex)If temperature range is 0 to 400° C and hysteresis is $0.5\%(2^{\circ}$ C), therefore when the set value is 300°C, 301°C:OFF and 299°C:ON.

Proportional control



*If the temperature is getting higher, ON time will be shorter.

Pulse output type of ON/OFF such as Relay output or SSR output(Voltage output) are ON/OFF repeatedly with constant cycle. When the PV and SV is the same, the output value will be 50% and ON/OFF time rate is 1:1.

How to select ON/OFF or proportional by plug pin

Control mode selection by plug pin




Function


- ●BURN OUT detection function: Make the output OFF when the thermocouple is broken
- The output is 24VDC \pm 3V 20mA max for driving external SSR.
- •Direct/Reverse operation: Reverse operation is the output ON when the display value is lower than set value, Direct operation is for cooler. *This product operates as reverse operation.

Load connection

●SSR output



●Relay output



Applications

	Food	Packaging machinery, Banding machinery
	Plastic	Plastic machinery, Film making system, etc.
	Industry	Electric furnace, Auto soldering machine, Drying machine, etc.
	Textile□	Body press, Textile machine, Sizing machine
	Etc.□	Cement making machinery
•		

Caution for using

- . Installation environmen
- 1) It shall be used indoor
- ②Altitude Max. 2000m
- 3 Pollution Degree 2
- ④Installation Category II
- 2. Please use the terminal(M3.5, Max.7.2mm) when
- connect the AC power source. 3. Please use separated line from high voltage line or power line in order to avoid
- 4. Please install power switch or circuit-breaker in order to cut power supply off.
- 5. The switch or circuit-breaker should be installed near by users.6. Do not use this product as Volt-meter or Ampere-meter, this is a temperature
- 7. Be sure to use compensating wire when extends wire from controller, otherwise
- the temperature deviation will be occurred at the part where wires are connected each other. 8. In case of using RTD sensor, 3wire type must be used.
- If it needs to extend the line, 3wires must be used with the same thickness as the line. It might cause the deviation of temperature if the resistance of line is different
- 9. In case of making power line and input signal line close, line filter for noise protection should be installed at power line and input signal line should be
- 10. Keep away from the high frequency instruments. (High frequency welding machine & sewing machine, big capacitive SCR controller)
- 11. When change the control mode, please apply power after change the mode
- 12. Do not connect power line on No.4, 5, 7 of terminal block for the sensor
- *It may cause malfunction if above instructions are not followed.

Main products

Fiber optic sensors ■ Temperature/Humidity transducer SSR/Power controllers Door sensors

Panel meters

■ Door side sensors ■ Counters

■ Proximity sensors

■ Pressure sensors ■ Tachometer/Pulse(Rotary encoders ■ Display units

■ Connector/Sockets
■ Sensor controller

Switching mode power supplies
Control switches/Lamps/Buzzers

I/O Terminal Blocks & Cables

■ Graphic/Logic panels Field network devices Laser marking system(Fiber, CO₂, Nd:YAG) 18, Bansong-ro 513beon-gil, Haeundae-gu, Busan, Korea

■ OVERSEAS SALES:
#402-404, BuLLes:
#402-404, BuLbenon Techno Park, 655, Pyeongcheon-ro,
Wommi-gu, Bucheon, Gyeonggi-do, Korea
TEL: 82-32-310-2730 / FAX: 82-32-329-0728

■ E-mail: sales@autonics.com

■ HEAD QUARTERS:

Autonics Corporation

http://www.autonics.com

Satisfiable Partner For Factory Automation

EP-KE-03-0061B